



VILLAGE OF LYTTON 2025 WATER SYSTEM REPORT



Kevin Vilac PO CWP CWWP

Community Water System

Introduction

The Village of Lytton is the purveyor of drinking water to users connected to the Village of Lytton Community Water System. This report is provided to the Village of Lytton Council, Lytton First Nation, and Interior Health for their information, and in fulfillment of the Village's obligations under the Provincial Drinking Water Protection Act and associated regulations, the terms and conditions of the Village's Water Service Agreement with Lytton First Nation and the Village's Water System Operating Permit issued by Interior Health. Enforcement of the regulations and issuance of water system permits is the responsibility of Interior Health Authority's Drinking Water Officer.

Water Consumption


Raw water for the Village of Lytton water system is supplied from Lytton Creek. When the creek does not meet the required drinking water parameters, the Village of Lytton water system is supplied with water from two wells, Well #2 and Well #3. The Creek supplied 102 525 000 litres of water, and the Wells provided 71 448 000 litres of water for a total of 173 973 000 litres consumed within the Village of Lytton water system in 2025. This was an increase in consumption of 4 % from 2024. The maximum daily demand peaked at 908 000 litres on April 14, 2025, while the minimum daily demand occurred on December 1, 2025, at 126 000 litres.

The water consumption for the Village of Lytton in 2025 averaged 476 638 litres per day. The maximum day (April 14th) water consumption was 6 053 litres per person, while the minimum day (Dec 1st) consumption was 840 litres per person. The average was 3 178 litres per person in the Village of Lytton every day of the year (based on a population of 150); average daily consumption in British Columbia is only 465 litres per capita (2021 Stats Canada Survey of Drinking Water Plants). The consumption rate per person is extremely high for the Village of Lytton, some of this can be contributed to construction activities, Village maintenance/recovery operations and water leaks.


The Village of Lytton must continue to reduce water consumption through identifying and repairing water leaks and enforcing water restrictions. The Province of British Columbia faced its fourth consecutive year of drought in 2025 and to maintain water supplies entering another potential drought in 2026 the Village of Lytton must find ways to conserve water to ensure supply for the future.


Community Water System

Total Water Use 2024-2025



Average Daily Water Use





Water Storage

The water storage capacity is just over 1.3 million litres between three reservoirs, 345 North Reservoir 445 m³, 345 South Reservoir 480 m³, and 265 Reservoir 360 m³. The Village’s distribution system accounts for another approximately 115 thousand litres. Distribution piping sizes range from 50mm to 200 mm, approximately 6.5 Km in total length.

Community Water System

Water Production

The primary drinking water source is Lytton Creek. The intake is located approximately 1km upslope and east of the Trans-Canada Highway. The Village also has two backup sources, Well 2 and Well 3.

- **Lytton Creek – rated 20 L/sec**
- **Well #2 – rated 7 L/sec**
- **Well #3 – rated 7 L/sec**

In the event of a power outage the Water Treatment Plant is powered by a backup diesel generator. The Creek intake is a gravity fed system. The valve which controls the flow is located within the Water Treatment Plant. The Village also has a portable generator that can power one of the Well sites in the event of a power failure and the Creek supply

does not meet the mandatory water quality guidelines.



Water Treatment Systems

The Village of Lytton has Trojan Swift low pressure UV reactors followed by Chlorination that is mixed within the 345 Reservoirs. The Reservoirs provide appropriate contact time before being distributed to ensure a minimum Free Chlorine residual of 1.20 mg/L as outlined within the Operating Permit.

The Village of Lytton follows Interior Health's 4-3-2-1-0 Drinking Water Objectives.

- 4 log inactivation of Viruses (99.99%)
- 3 log removal or inactivation of Giardia Lamblia and Cryptosporidium (99.9%)
- 2 refers to two treatment processes.
- 1 for less than 1 NTU of Turbidity
- 0 total and fecal coliforms and E. coli

Trojan Swift UV Reactors



Community Water System

Quality Monitoring



WTP Generator


Drinking water delivered to users of the Village's system is subject to a comprehensive and rigorous testing program that ensures quality drinking water. Water samples from up to seven (7) separate locations within the system were sent in 2025, on a weekly basis, to *Caro Analytical Services* laboratories to be tested for the presence/absence of *E. coli* and Total Coliform Bacteria. The Village also performs quarterly testing to monitor for any Disinfection Byproducts. The Village of Lytton staff also perform Chlorine residual testing, and Turbidity testing to ensure the water is potable.

The standard protocol when a water sample is found to contain the presence of Coliform (an early indicator that we could have a problem arising), however minute, is to flush and resample the water immediately at the same location and resubmit for testing. The Regional Drinking Water Officer will determine if any further action

by the Village is necessary.

The water is monitored 24/7 with our water quality monitoring devices. These devices will monitor in real time Flow, Temperature, Turbidity, UVT, PH and Chlorine residual when the system is operating. The quality control and accuracy of monitoring increases with these devices online. All information is logged on the SCADA system in the Water Treatment Plant. With this real time monitoring the Operators can instantly check the water quality and tell if a problem is arising.

Cross Connection Control Program



As the Village is rebuilt it will have to develop a Cross-connection Control Program for the Village of Lytton. This program is designed to inspect and eliminate any possible connections between the potable water system and any other connections that are not potable. For example, a connection to potable water and a sprinkler system that injects fertilizer could possibly contaminate the whole water system without the proper back flow device in place.

Community Water System

Records

The Village of Lytton completed upgrading to an automated and continuous operating system to monitor Flow, Ph., Turbidity, Water temperature, Chlorine residual and Reservoir levels. This system is called SCADA, *Supervisory Control and Data Acquisition*, and it assists Village staff with maintaining a safe drinking water supply by advising of any monitored change within the water system. The SCADA system will alert staff to ensure that corrections can be made before water levels or water quality can be adversely affected.

Test records are stored on Interior Health's website

<https://services.interiorhealth.ca/publichealthprotection/watersamples.aspx>

Appendix A has the test results for disinfection by-products which was sampled March, June, September and December from 345 South Reservoir.

Operation

The Village of Lytton Community Water System and Water Treatment facilities are operated and maintained by highly trained and certified operators. The SCADA system will continuously monitor the water quality which in turn assists the operators to make necessary adjustments to meet or exceed the provincial drinking water quality objectives established by Interior Health as well as federal Canadian Drinking Water Quality objectives. Water distribution work is also carried out by staff certified for their tasks: water main leak repair, water service installation, and fire hydrant maintenance. Special tasks such as reservoir cleaning, leak detection and water main replacement are undertaken by qualified contractors with the proper equipment and experience to complete the work.

2025 Operations Staff

- Kevin Vilac
 - - EOCB Wastewater Treatment IV
 - - EOCB Water Distribution IV
 - - EOCB Water Treatment MU II
 - - EOCB Wastewater Collections MU II
 - - BCWWA Chlorine Handling Certificate
 - - ABC Class II Wastewater Treatment Professional Operator
 - Cross Connection Control Inspector Certificate
- Morgan Heaster – EOCB Small Water Systems Certification
 - EOCB Small Wastewater Systems Certification
- Gene McArthur - EOCB Small Water Systems Certification
- Edmund Justice – Operator in Training

Maintenance / Capital Projects – 2025

- Completed the replacement of the water main on Alonzo Way between 5th and 4th.
- Completed the replacement of the water main on Station Rd from 5th to 7th.
- Completed the replacement of the water main on 6th from Main St to Station Rd.
- Completed the water main loop on 7th St from Alonzo to Station Rd.
- Serviced UV reactors 1 & 2.
- Serviced the Altitude Valve at Reservoir 265
- Cleaned the Creek intake twice.
- Water Intake assessment completed.
- 166 Weekly water samples.

Initiatives – 2026

In 2026 the Village will continue to identify and repair water leaks and replace old infrastructure. The Village will also work towards a complete Source Water Protection Plan, Drought response plan and an Emergency Response Plan. With these plans and programs in place, it is a positive step forward in protecting the Village's drinking water system. The Village also has planned multiple water main upgrades, cooling for Well 2 kiosk and 5 water sampling stations throughout the Village. The Village is also planning to replace the water meter at IR 18 and install a water meter at IR 17.



Community Water System

Future Water Quality

The Village of Lytton will have to work towards finding and eliminating existing water leaks as the water consumption is far greater than it should be. Through ongoing training, monitoring and responsible planning the Village will be able to ensure potable water for its consumers. The Village will also have to implement water conservation strategies to ensure water for future generations.



Conclusion

The Village of Lytton Employees work hard in the effort to maintain, ensure proper water usage, identify and repair water leaks, monitor water quantity, monitor water quality, and educate the public whenever possible. With these goals the Village of Lytton should be able to maintain a quality water source and distribution system for many years to come.

This 2025 Village of Lytton Water System Report is presented to the public, by way of posting on the Village of Lytton website, as required by the British Columbia Drinking Water Protection Act and Regulations, as well as to meet the terms and conditions of the Village's Water System Operating Permit issued by Interior Health's Drinking Water Officer.

Community Water System

Appendix "A"

Page : 3 of 3
 Work Order : KS2500875
 Client : Village of Lytton
 Project : Quarterly Water Samples



Analytical Results

Sub-Matrix: Water		Client sample ID		South Reservoir						
(Matrix: Water)		Sampling date/time		13-Mar-2025 09:00						
Analyte	Method/Lab	LOR	Unit	KS2500875-001	BCDWQG MAC					
Organic / Inorganic Carbon										
Carbon, dissolved organic [DOC]	E358-LVA	0.50	mg/L	0.97	RRV	--	--	--	--	--
Carbon, total organic [TOC]	E355-LVA	0.50	mg/L	0.53	RRV	--	--	--	--	--
Volatile Organic Compounds [THMs]										
Bromodichloromethane	E811B/NVA	1.0	µg/L	<1.0		--	--	--	--	--
Bromoform	E811B/NVA	1.0	µg/L	<1.0		--	--	--	--	--
Chloroform	E811B/NVA	1.0	µg/L	1.7		--	--	--	--	--
Dibromochloromethane	E811B/NVA	1.0	µg/L	<1.0		--	--	--	--	--
Trihalomethanes [THMs], total	E811B/NVA	2.0	µg/L	<2.0	100 µg/L	--	--	--	--	--
Bromofluorobenzene, 4-	E811B/NVA	1.0	%	82.8		--	--	--	--	--
Difluorobenzene, 1,4-	E811B/NVA	1.0	%	97.7		--	--	--	--	--
Haloacetic Acids										
Bromochloroacetic acid	E750/WT	1.00	µg/L	<1.00		--	--	--	--	--
Dibromoacetic acid	E750/WT	1.00	µg/L	<1.00		--	--	--	--	--
Dichloroacetic acid	E750/WT	1.00	µg/L	<1.00		--	--	--	--	--
Monobromoacetic acid	E750/WT	1.00	µg/L	<1.00		--	--	--	--	--
Monochloroacetic acid	E750/WT	1.00	µg/L	<1.00		--	--	--	--	--
Trichloroacetic acid	E750/WT	1.00	µg/L	<1.00		--	--	--	--	--
Haloacetic acids, total [HAA5]	E750/WT	5.00	µg/L	<5.00	80 µg/L	--	--	--	--	--

Please refer to the General Comments section for an explanation of any result qualifiers detected.
 Please refer to the Accreditation section for an explanation of analyte accreditations.

No Breaches Found

Key:
 BCDWQG British Columbia Drinking Water Quality Guidelines (JAN, 2023)
 MAC Maximum Acceptable Concentrations

Community Water System

Work Order : KS2502251
Client : Village of Lytton
Project : Quarterly Water Samples



Analytical Results

Analyte	CAS Number	Method/Lab	Client sample ID		Client sampling date / time	south reservoir																		
			LOR	Unit		KS2502251-001																		
Sample Preparation																								
Disinfectant carbon filtration location		EP368/VA	-	-	fed																			
Organic / Inorganic Carbon																								
Carbon, dissolved organic (DOC)		E358-L/VA	0.50	mg/L	3.42																			
Carbon, total organic (TOC)		E355-L/VA	0.50	mg/L	2.78																			
Volatile Organic Compounds (THMs)																								
Bromochloromethane	75-27-4	E611B/VA	1.0	µg/L	<1.0																			
Bromofom	75-29-2	E611B/VA	1.0	µg/L	<1.0																			
Chloroform	67-68-3	E611B/VA	1.0	µg/L	103																			
Dibromochloromethane	124-48-1	E611B/VA	1.0	µg/L	<1.0																			
Trichloroethane (THM5), total		E611B/VA	2.0	µg/L	103																			
Volatile Organic Compounds (THMs) Surrogates																								
Bromofluorobenzene, 4-	480-00-4	E611B/VA	1.0	%	86.8																			
Difluorobenzene, 1,4-	640-39-3	E611B/VA	1.0	%	99.2																			
Halocacetic Acids																								
Bromochloroacetic acid	5589-94-8	E750/WT	1.00	µg/L	<1.00																			
Dibromoacetic acid	631-44-1	E750/WT	1.00	µg/L	<1.00																			
Dichloroacetic acid	79-43-6	E750/WT	1.00	µg/L	38.7 DLHC																			
Monochloroacetic acid	79-09-3	E750/WT	1.00	µg/L	<1.00																			
Monochloroacetic acid	79-11-8	E750/WT	1.00	µg/L	2.07																			
Trichloroacetic acid	76-03-9	E750/WT	1.00	µg/L	62.6 DLHC																			
Halocacetic acids, total (HAA5)	na	E750/WT	5.00	µg/L	103																			

Please refer to the General Comments section for an explanation of any result qualifiers detected.

No Breaches Found

Community Water System

Work Order : KS2503695
 Client : Village of Lytton
 Project : Quarterly Water Samples



Analytical Results

Analyte	CAS Number	Method/Lab	Client sample ID		south reservoir		BCDWGQ MAC						
			LOR	Unit	Client sampling date / time								
SubMatrix: Water (Matrix: Water)													
Sample Preparation													
Dissolved carbon filtration location		EP328/VA	-	-	fed								
Organic / Inorganic Carbon													
Carbon, dissolved organic [DOC]		E358-L/VA	0.50	mg/L	0.91								
Carbon, total organic [TOC]		E355-L/VA	0.50	mg/L	0.66								
Volatile Organic Compounds [THMs]													
Bromochloromethane	75-27-4	E6118/VA	1.0	µg/L	<1.0								
Bromotoluene	75-28-2	E6118/VA	1.0	µg/L	<1.0								
Chlorotoluene	67-66-3	E6118/VA	1.0	µg/L	2.1								
Dibromochloromethane	124-48-1	E6118/VA	1.0	µg/L	<1.0								
Trihalomethanes [THM5], total		E6118/VA	2.0	µg/L	2.1	100 µg/L							
Volatile Organic Compounds [THMs] Surrogates													
Bromofluorobenzene, 4-	402-02-4	E6118/VA	1.0	%	84.1								
Difluorobenzene, 1,4-	540-36-3	E6118/VA	1.0	%	98.9								
Halogenated Acids													
Bromochloroacetic acid	5589-56-8	E750/WT	1.00	µg/L	<1.00								
Dibromoacetic acid	631-64-1	E750/WT	1.00	µg/L	<1.00								
Dichloroacetic acid	79-43-6	E750/WT	1.00	µg/L	<1.00								
Monobromoacetic acid	79-09-3	E750/WT	1.00	µg/L	<1.00								
Monochloroacetic acid	79-11-8	E750/WT	1.00	µg/L	<1.00								
Trichloroacetic acid	76-03-9	E750/WT	1.00	µg/L	<1.00								
Halooacetic acids, total [HAA5]	n/a	E750/WT	5.00	µg/L	<5.00	80 µg/L							

Please refer to the General Comments section for an explanation of any result qualifiers detected.

No Breaches Found

Community Water System

Work Order : KS2505160
Client : Village of Lytton
Project : Quarterly Water Samples



Analytical Results

Analyte	CAS Number	Method/Lab	LOR	Unit	Client sample ID	south resevoir				
					Client sampling date / time	17-Dec-2025 08:20	KS2505160-001	BCDWQG	MAC	
Sample Preparation										
Dissolved carbon filtration location	---	EP368/VA	-	-	field	---	---	---	---	---
Organic / Inorganic Carbon										
Carbon, dissolved organic [DOC]	---	E358-L/VA	0.50	mg/L	0.88	---	---	---	---	---
Carbon, total organic [TOC]	---	E355-L/VA	0.50	mg/L	0.99	---	---	---	---	---
Volatle Organic Compounds [THMs]										
Bromodichloromethane	75-27-4	E611B/VA	1.0	µg/L	<1.0	---	---	---	---	---
Bromoform	75-25-2	E611B/VA	1.0	µg/L	<1.0	---	---	---	---	---
Chloroform	67-68-3	E611B/VA	1.0	µg/L	14.3	---	---	---	---	---
Dibromochloromethane	124-48-1	E611B/VA	1.0	µg/L	<1.0	---	---	---	---	---
Trihalomethanes [THMs], total	---	E611B/VA	2.0	µg/L	14.3	100 µg/L	---	---	---	---
Volatle Organic Compounds [THMs] Surrogates										
Bromofluorobenzene, 4-	480-00-4	E611B/VA	1.0	%	97.4	---	---	---	---	---
Difluorobenzene, 1,4-	540-36-3	E611B/VA	1.0	%	94.3	---	---	---	---	---
Halooacetic Acids										
Bromochloroacetic acid	5589-99-8	E750/WT	1.00	µg/L	<1.00	---	---	---	---	---
Dibromoacetic acid	631-84-1	E750/WT	1.00	µg/L	<1.00	---	---	---	---	---
Dichloroacetic acid	79-43-6	E750/WT	1.00	µg/L	6.37	---	---	---	---	---
Monobromoacetic acid	79-08-3	E750/WT	1.00	µg/L	<1.00	---	---	---	---	---
Monochloroacetic acid	79-11-8	E750/WT	1.00	µg/L	<1.00	---	---	---	---	---
Trichloroacetic acid	79-03-9	E750/WT	1.00	µg/L	10.6	---	---	---	---	---
Halooacetic acids, total [HAA5]	n/a	E750/WT	5.00	µg/L	17.0	80 µg/L	---	---	---	---

Please refer to the General Comments section for an explanation of any result qualifiers detected.

No Breaches Found