



Water Quality Advisory

The Village of Lytton is issuing a water quality advisory. A water quality advisory informs the public that:

- There is some level of risk associated with consuming the drinking water; and,
- This risk is elevated for people with weakened immune systems.
- A boil water notice is not required at this time.

On the morning of February 27, 2026, we experienced a failure of our Turbidity meter on the Creek Raw water supply at the Water Treatment Plant. Due to this failure, we experienced elevated Turbidity which reduced the effectiveness of the Ultraviolet Disinfection of the water. The chlorine levels are within the normal range. We have switched to the Wells until the Turbidity meter problem can be resolved.

THIS WATER QUALITY NOTICE IS EFFECTIVE February 27, 2026 UNTIL FURTHER NOTICE.

ENQUIRIES?

Please call Village of Lytton office: 250-455-2355

Interior Health – Drinking Water Officer 250-851-7340

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.

Signature:

A handwritten signature in blue ink, appearing to read "Diane Mombourquette", written over a horizontal line.

Diane Mombourquette CAO, Village of Lytton